1 Q. RE: p. B-20 Are SCADA, JDE, Lotus Notes, and telephone circuits to the 2 Holyrood Generating Station, and teleprotection circuits for transmission lines 3 TL242, TL218 and TL217, supported or supportable by existing or obtainable 4 non-Hydro owned telecommunications facilities to the Holyrood Plant and 5 Generating Station? 6 7 8 A. The reliability of the power system is contingent on the availability of the 9 telecommunications network. To guarantee this high availability the majority 10 of the telecommunication network is owned and maintained by the Company 11 with alternate routing of critical voice and data circuits leased from Aliant 12 Communications (Aliant).