

1 **Microwave Site Refurbishing, p. B-101, \$407,000**

2 Q. What has been the practice of NLH with regard to the inspection of the sites
3 in the West Coast Microwave Site infrastructure?

4

5

6 A. The West Coast Microwave Sites are inspected on an annual basis. The
7 inspection includes a climbing inspection of the tower, including bolts and
8 guy wires, assessment of general site condition, and minor repairs as
9 required.