	CA-279
	(1 <sup>st</sup> Revision)
	February 12, 2003
Requests for Information	NP 2003 GRA

- 1Q.In reference to the evidence of Earl Ludlow, page 37, tables 20 and 21, and page 40,2Table 22, is it fair to conclude on the basis of Table 22 that Newfoundland Power3has failed to improve its overall system SAIDI and SAIFI statistics in recent years;4i.e., all improvements in SAIDI and SAIFI experienced by Newfoundland Power5customers are owing to improvements made by Hydro?6
- A. No, it is not fair to conclude that Newfoundland Power has failed to improve its system
   reliability statistics in recent years.

Table 1 below provides an operating area breakdown of the statistics presented in Table 22 on Page 40 of the *Operations & Customer Service Evidence*. These statistics exclude outages caused by both scheduled and unscheduled loss of supply from Hydro.

1	2
1	3

10

11

Table 1									
SAIFI/SAIDI by Operating Area: 1998 to 2002									
Area	Measure	Year							
		1998	1999	2000	2001	2002 <sup>1</sup>			
St. John's	SAIFI	2.41	2.79	3.11	2.56	1.72			
St. Juni S	SAIDI	2.27	6.89	4.79	1.84	1.74			
Avalon	SAIFI	3.37	5.00	3.67	3.48	2.08			
Avaion	SAIDI	5.95	15.79	4.12	3.71	2.97			
Burin	SAIFI	5.88	6.22	7.45	4.32	8.72			
Durin	SAIDI	13.57	9.82	10.98	8.02	8.85			
Bonavista	SAIFI	4.20	6.41	3.66	3.62	7.08			
Donavista	SAIDI	6.59	5.79	3.50	4.95	7.95			
Candar	SAIFI	4.60	5.88	5.69	2.78	6.27			
Gander	SAIDI	7.14	12.49	7.76	4.16	11.28			
Grand Falls	Grand Falls SAIFI	1.58	5.38	5.43	3.37	2.92			
Grand Fails	SAIDI	2.20	9.56	6.74	5.10	4.43			
	SAIFI	3.17	5.66	3.68	1.78	2.75			
<b>Corner Brook</b>	SAIDI	3.97	5.38	3.17	2.03	2.70			
G4 L 'II	SAIFI	4.60	16.05	5.46	3.95	3.79			
Stephenville	SAIDI	10.62	13.64	6.58	5.34	6.16			

14

15

 $^{1} < >$ 

In order to properly assess trends in SAIDI and SAIFI reliability statistics, it is necessary
to review longer-term (3 to 5 year) averages. These reduce the effects of year-to-year
weather variations. The statistics presented in Table 1 show that Newfoundland Power
has made progress in improving the reliability of its system over much of its service
territory. These improvements, together with those achieved by Hydro in reducing the
frequency and duration of loss of supply outages, have resulted in reliability
improvements for the Company's customers.