

1 **Q. In reference to the evidence of Lorne Henderson, page 10, lines 2 to 4, how will this**
2 **equipment be utilized following completion of the load research program?**

3
4 A. Upon completion of the load research program the equipment may be relocated and used
5 in other research applications such as time-of-use monitoring or may be used for
6 compliance monitoring of customers on the Curtailment Service Option. In addition,
7 because the load research meters installed at each sample point replace the billing meter
8 currently in service, those not reused in other special applications could potentially be
9 used to collect meter reading data for billing purposes on an ongoing basis.