

*Requests for Information*

1 **Q. In reference to the evidence of Earl Ludlow, page 37, Table 20, please provide a**  
2 **similar table for the period 1992 to 2002. Please provide particulars as to how the**  
3 **Company is forecasting SAIFI and SAIDI to the end of 2002.**

4  
5 A. Table 1 below provides Newfoundland Power's SAIFI and SAIDI statistics for 1992 to  
6 < > 2002.  
7

Table 1 SAIFI and SAIDI: 1992 to 2002 <sup>1</sup>											
Year	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002
SAIFI <sup>2</sup>	5.74	4.77	4.99	6.56	3.82	4.01	5.60	6.61	4.93	3.99	4.76
SAIDI <sup>3</sup>	7.49	5.50	23.70	6.68	4.22	4.62	7.41	9.71	5.93	3.73	4.54

8 <sup>1</sup> Includes scheduled and unscheduled interruptions.

9 <sup>2</sup> Average number of interruptions per customer.

10 <sup>3</sup> Average hours of interruption per customer.

11  
12 Forecasts of SAIFI and SAIDI are based on the monthly year-to-date actuals; plus an  
13 average for the remaining months based on the previous three years, times an  
14 improvement factor. < >

15  
16 < >