

1 **Q. In reference to the evidence of Earl Ludlow, page 37, Table 20, please repeat the**
2 **table for the years 1992 to current, excluding scheduled interruptions.**

3
4 A. Table 1 below provides Newfoundland Power's SAIFI and SAIDI statistics (excluding
5 scheduled interruptions) for 1992 to 2002. SAIFI and SAIDI statistics are not forecast
6 based on exclusion of scheduled interruptions. The 2002 statistics reflect actuals to year-
7 end.
8

Table 1 SAIFI and SAIDI: 1992 to 2002¹											
Year	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002
SAIFI ²	5.09	3.84	4.14	5.58	2.98	3.25	4.78	5.34	3.42	3.08	3.74
SAIDI ³	6.58	4.36	22.26	5.20	2.57	3.54	5.79	7.73	3.51	2.26	3.16

9 ¹ Excludes scheduled interruptions.

10 ² Average number of interruptions per customer.

11 ³ Average hours of interruption per customer.