

1 **Q. In reference to the evidence of Earl Ludlow, page 40, Table 22, please provide a**
2 **similar table for the period 1992 to current forecast.**

3
4 A. Table 1 below provides Newfoundland Power's SAIFI and SAIDI statistics (excluding
5 loss of supply outages) for 1992 to forecast 2002.
6

Table 1											
SAIFI and SAIDI: 1992 to 2002F¹											
Year	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002F
SAIFI ²	3.46	3.68	4.38	3.70	2.66	2.72	3.21	5.28	4.11	2.99	3.75
SAIDI ³	4.75	4.64	19.53	5.34	3.87	3.73	4.91	9.36	5.33	3.43	5.08

7 ¹ Excludes loss of supply outages.

8 ² Average number of interruptions per customer.

9 ³ Average hours of interruption per customer.

10
11 Actual SAIFI and SAIDI statistics (excluding loss of supply outages) for 2002 are 3.25
12 and 4.19 respectively.