

*Requests for Information*

---

1 **Q. In reference to the evidence of Earl Ludlow, page 40, Table 22, please provide a**  
2 **similar table for the period 1992 to current forecast.**

3  
4 A. Table 1 below provides Newfoundland Power's SAIFI and SAIDI statistics (excluding  
5 loss of supply outages) for 1992 to < > 2002.  
6

Table 1 SAIFI and SAIDI: 1992 to 2002 <sup>1</sup>											
Year	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002
SAIFI <sup>2</sup>	3.46	3.68	4.38	3.70	2.66	2.72	3.21	5.28	4.11	2.99	3.25
SAIDI <sup>3</sup>	4.75	4.64	19.53	5.34	3.87	3.73	4.91	9.36	5.33	3.43	4.18

7  
8 <sup>1</sup> Excludes loss of supply outages.

9 <sup>2</sup> Average number of interruptions per customer.

10 <sup>3</sup> Average hours of interruption per customer.

11  
12 < >