

1 **Q. Has Newfoundland Power calculated its portion of customer rated distribution costs**  
2 **using the zero intercept method? If so, please provide a copy of the calculation?**  
3

4 A. Newfoundland Power uses the minimum distribution system analysis to assign customer  
5 costs related to distribution lines, poles and fittings. The Company uses the zero-  
6 intercept method to classify customer costs related to distribution transformers. A copy  
7 of the zero-intercept analysis for distribution transformers is contained in Exhibit LBB-3,  
8 Appendix B.