1

Q.

annual demand and energy supply showing purchases from Newfoundland and Labrador Hydro, Newfoundland Power, losses and total supply.

For the period 1997 to 2001 provide a table of actual versus prior year forecast

A. Table 1 below provides actual energy supply and demand for 1997 to 2001.

Table 1 Actual Energy Supply and Demand (GWh) ¹							
	1997	1998	1999	2000	2001		
Supply							
Purchased	4,243.5	4,258.9	4,291.9	4,432.3	4,494.9		
Produced	424.2	429.4	450.0	423.1	416.1		
Total Supply	4,667.7	4,688.3	4,741.9	4,855.4	4,911.0		
Demand							
Energy Sales	4,438.0	4,439.6	4,499.7	4,554.8	4,666.7		
Company Use	12.2	11.5	11.2	11.5	11.8		
Losses	217.5	237.2	231.0	289.1	232.5		
Total Demand	4,667.7	4,688.3	4,741.9	4,855.4	4,911.0		

1. Actual data are adjusted for weather.

12

13

Table 2 on page 2 provides Newfoundland Power's forecasts of energy supply and demand for the period from 1997 to 2001. These forecasts were prepared in the year immediately prior to the year indicated in the column headings.

14 15

Table 2 Forecast Energy Supply and Demand (GWh)							
	1997	1998	1999	2000	2001		
Supply							
Purchased	4,207.3	4,243.3	4,299.5	4,358.4	4,401.9		
Produced	424.8	434.7	453.0	450.6	431.3		
Total Supply	4,632.1	4,678.0	4,752.4	4,809.0	4,833.2		
Demand							
Energy Sales	4,400.5	4,443.7	4,516.4	4,558.5	4,592.3		
Company Use	14.8	12.8	11.7	11.1	11.3		
Losses	216.8	221.5	224.3	239.4	229.6		
Total Demand	4,632.1	4,678.0	4,752.4	4,809.0	4,833.2		