

Requests for Information

Q. For the period 2002 to 2007 provide a table of forecast annual demand and energy supply showing purchases from Newfoundland and Labrador Hydro, Newfoundland Power, losses and total supply.

A. Table 1 below provides forecast energy supply and demand for 2003 to 2007 based on existing rates. The forecast information requested for 2002 is provided along with the actual 2002 information in the Company's response to Request for Information NLH-214 (1st Revision).

Table 1 Forecast Energy Supply and Demand (GWh) Based on Existing Rates					
	2003	2004	2005	2006	2007
Supply					
Purchased	4,694.7	4,771.3	4,773.8	4,838.3	4,934.5
Produced	425.1	426.1	426.1	426.1	426.1
Total Supply	5,119.8	5,197.4	5,199.9	5,264.4	5,360.6
Demand					
Energy Sales	4,852.0	4,926.1	4,928.7	4,987.5	5,078.9
Company Use	11.8	11.8	11.8	11.8	11.8
Losses	256.0	259.5	259.4	265.1	269.9
Total Demand	5,119.8	5,197.4	5,199.9	5,264.4	5,360.6

Power produced by Newfoundland Power in 2003 is forecast based on adjusted normal hydro production of 425.1 GWh < >. Normal hydro production for 2004 and beyond is forecast to be 426.1 GWh.