

PUB 1.0

(RE: p. 9 & 10 of 82)

Hydro Plants Facility Rehabilitation (\$2,345,000)

PUB 1.7

Q. Provide a table showing for each of the Company's 23 hydroelectric plants the annual normal production for each of the years from 1999 to 2002 (forecast as of July 31, 2002) and the actual production for each of these three years (2002 forecast as of July 31, 2002).

A. The following table provides, for each of the Company's hydroelectric plants, the annual normal production and the annual actual production for the years 1999 to 2002. The estimates of actual production for 2002 are based on the Company's forecast as of July 31, 2002.

Plant	1999		2000		2001		2002	
	Normal	Actual	Normal	Actual	Normal	Actual	Normal	Forecast
Petty Harbour	17.0	10.1	15.9	15.4	15.9	16.1	15.9	13.3
Pierre's Brook	27.7	22.2	25.3	24.3	25.3	24.7	25.3	26.6
Tors Cove	26.0	26.0	26.3	22.5	26.3	25.9	26.3	25.8
Rocky Pond	14.5	15.1	14.2	12.6	14.2	14.3	14.2	14.0
Mobile	46.3	44.1	41.8	42.5	41.8	38.1	41.8	39.2
Cape Broyle	34.5	30.2	34.2	31.2	32.4	31.8	34.2	33.8
Horsechops	50.1	33.6	43.7	34.6	43.7	41.1	43.7	45.9
Topsail	13.1	12.0	14.2	13.3	14.2	12.5	14.2	11.8
Seal Cove	10.1	9.7	8.8	8.4	8.8	8.8	6.6	5.9
Heart's Content	8.5	10.0	8.2	8.6	8.2	8.8	8.2	8.8
Victoria	3.1	3.0	3.0	2.8	3.0	2.8	3.0	2.6
New Chelsea	15.4	17.8	15.4	14.5	15.4	14.9	15.4	13.8
Pittmans	2.6	3.3	3.0	2.8	3.0	2.8	3.0	2.8
Morris	7.3	4.4	7.2	5.6	7.2	5.4	7.2	6.9
West Brook	3.5	2.6	2.8	1.6	2.8	2.8	2.8	3.2
Fall Pond	1.1	1.5	1.0	1.3	1.0	0.8	1.0	1.0
Lawn	2.8	2.7	2.6	2.8	2.7	2.4	2.6	2.7
Rattling Brook	72.7	71.3	69.1	64.0	69.4	50.5	69.1	58.7
Sandy Brook	27.6	31.8	25.7	30.4	20.5	13.1	28.7	25.6
Lockston	8.0	9.0	8.4	9.4	8.4	7.5	8.4	8.5
Port Union	2.8	2.5	2.3	2.2	2.3	2.1	2.3	1.9
Lookout Brook	33.3	33.0	29.5	36.1	29.1	22.3	29.5	33.9
Rose Blanche	22.0	20.1	20.5	28.3	20.5	17.1	20.5	23.3
Totals	450.0	416.0	423.1	415.2	416.1	366.6	423.9	410.0