

Reconductor Section of GLD-01, Volume III, Distribution – Appendix 4, page 2 (\$80,000)

Q. Please provide the reliability indices for each of the past 5 years for each of feeders Glendale-01 and Hardwoods-04.

A. Table 1 provides a summary of the SAIFI and SAIDI data for Glendale-01 and Hardwoods-04 for the period 1998 to 2002 inclusive.

Table 1 Unscheduled Distribution Outage Performance Indicators For Glendale 01 and Hardwoods 04 Feeders¹				
Year	GDL-01		HWD-04	
	SAIFI	SAIDI	SAIFI	SAIDI
1998	0.79	0.78	0.02	0.03
1999	0.12	4.20	1.30	0.60
2000	0.16	0.40	1.06	1.01
2001	4.16	0.60	0.17	0.27
2002	1.51	1.71	4.04	3.34

¹ The SAIFI and SAIDI statistics exclude planned power interruptions and interruptions due to loss of supply from Hydro.