

Substations Appendix 4
Attachment A

Q. Doesn't the "Western Region – Corner Brook 2003 Five Year Forecast" of load growth imply that, other than in 2003, the installed capacity will meet or exceed demand for the period examined (2003 to 2008)?

A. The "Western Region – Corner Brook 2003 Five Year Forecast" that appears in Appendix 4, Attachment A, Appendix A indicates that the existing capacity at Bayview is 45 MVA. This load forecast assumes that a new 25 MVA transformer will be installed at Bayview (see note 3). The existing capacity, not considering any new transformation, is not sufficient to meet forecast demand in the study period.