

Production

Q. Recalculate the answer to PUB-18 for the period 2005 to 2008 taking in to account the expected production from Granite Canal.

A. The annual fuel savings achieved by operating Newfoundland Power's hydro plants will not be affected by the expected production from Granite Canal. All energy generated by both Hydro's and Newfoundland Power's hydro plants will reduce the amount that must be generated at the Holyrood plant. As outlined in the answer to question PUB-18 NP, the operation of Newfoundland Power's hydro plants while Holyrood is off line enables Hydro to retain water in their reservoirs, which will be used later to offset generation at Holyrood.