

1 **Distribution**

2

3 **Q. How many electromechanical feeder relays and oil-filled reclosers will NP need to**  
4 **replace in the next 5 years (B-26, Distribution System Remote Control)?**

5

6 A. Table 1 provides the number of electromechanical feeder relays and oil-filled reclosers  
7 that Newfoundland Power plans to replace in the next five years. Based on the current  
8 plan, all of the existing electromechanical relays will be replaced by the end of 2006.

9

<b>Year</b>	<b>Electromechanical Feeder Relays</b>	<b>Oil-filled Reclosers</b>
2004	25	6
2005	25	6
2006	29	9
2007	0	19
2008	0	19

10