

Q. DISTRIBUTION**PUB 18.0 (RE: p. 49 & 50 of 73) Distribution Reliability Initiative (\$872,000)****PUB 18.1**

Please provide for each of the five years summarized on p. 50 of 73 the average unscheduled distribution yearly interruption statistics for feeder GBY-02 (Carmanville/Gander Bay) excluding planned interruptions and loss of supply from NLH. Please include explanations for outages.

A. The table below provides a summary of the SAIFI and SAIDI statistics for GBY-02 for the period 1999 to 2003 inclusive.

| Newfoundland Power Inc. Feeder GBY-02 (Carmanville/Gander Bay) Unscheduled Distribution Outage Performance Indicators (Excluding Loss of Supply from NLH) | | | | |
|--|---|---------------------------------------|--------------------|--------------------|
| Year | Total Customer Interruptions | Total Customer Minutes | Total SAIFI | Total SAIDI |
| 1999 | 6,716 | 687,221 | 7.75 | 13.21 |
| 2000 | 1,945 | 248,035 | 2.17 | 4.64 |
| 2001 | 1,415 | 103,775 | 1.59 | 1.95 |
| 2002 | 2,950 | 481,559 | 3.27 | 8.90 |
| 2003 | 2,198 | 649,720 | 2.48 | 12.19 |

Attachment A contains the details of the individual outages including the cause of the outages for this feeder.

**Interruption Details – Unscheduled NP Distribution on
Feeder GBY-02**

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | |
|---------------------------|---|------------------------|---------------------|--------------------------------|
| Current Customers Served: | 879 | | | |
| Total Customers Affected: | 15224 | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | SAIDI: 41.15 | |
| Interruption #: | 85307 | Outage Ticket: | | |
| Started: | 1999-02-22 02:15PM | | | |
| Ended: | 1999-02-22 02:59PM | | | |
| Duration: | 44 - Minutes | # of Customers: | 10 | Customer Minutes: 440 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | CREW RE-TIED FLOATING PHASE | | | |
| Interruption #: | 85657 | Outage Ticket: | | |
| Started: | 1999-03-01 01:20PM | | | |
| Ended: | 1999-03-01 02:45PM | | | |
| Duration: | 85 - Minutes | # of Customers: | 6 | Customer Minutes: 510 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPL LEAD IN CUT-OUT | | | |
| Interruption #: | 86857 | Outage Ticket: | | |
| Started: | 1999-04-01 03:43PM | | | |
| Ended: | 1999-04-01 06:45PM | | | |
| Duration: | 182 - Minutes | # of Customers: | 1 | Customer Minutes: 182 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | FREDERICKTON REPAIRS TO SERVICE | | | |
| Interruption #: | 88077 | Outage Ticket: | | |
| Started: | 1999-05-22 04:45AM | | | |
| Ended: | 1999-05-22 05:30AM | | | |
| Duration: | 45 - Minutes | # of Customers: | 10 | Customer Minutes: 450 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | CARMANVILLE TRF LEAD | | | |
| Interruption #: | 88080 | Outage Ticket: | | |
| Started: | 1999-05-26 01:30PM | | | |
| Ended: | 1999-05-26 05:00PM | | | |
| Duration: | 210 - Minutes | # of Customers: | 1 | Customer Minutes: 210 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | LADLE COVE REPL 75 KVA TRF | | | |
| Interruption #: | 88115 | Outage Ticket: | | |
| Started: | 1999-05-28 10:00AM | | | |
| Ended: | 1999-05-28 10:37AM | | | |
| Duration: | 37 - Minutes | # of Customers: | 832 | Customer Minutes: 30784 |
| Cause: | UNEXPLAINED | | | |
| Comments: | CARMANVILLE GBY 02 FEEDER ON NON RECLOSE @ TIME OFF OUTAGE | | | |
| Interruption #: | 88700 | Outage Ticket: | | |
| Started: | 1999-06-28 08:57AM | | | |
| Ended: | 1999-06-28 02:00PM | | | |
| Duration: | 303 - Minutes | # of Customers: | 1 | Customer Minutes: 303 |
| Cause: | LIGHTNING | | | |
| Comments: | DAVIDSVILLE LIGHTNING | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | |
|---------------------------|---|------------------------|---------------------|---------------------------------|
| Current Customers Served: | 879 | | | |
| Total Customers Affected: | 15224 | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | SAIDI: 41.15 | |
| Interruption #: | 89132 | Outage Ticket: | | |
| Started: | 1999-07-05 10:48AM | | | |
| Ended: | 1999-07-05 12:00PM | | | |
| Duration: | 72 - Minutes | # of Customers: | 1 | Customer Minutes: 72 |
| Cause: | LIGHTNING | | | |
| Comments: | CARMANVILLE LIGHTNING | | | |
| Interruption #: | 89891 | Outage Ticket: | | |
| Started: | 1999-08-07 10:50PM | | | |
| Ended: | 1999-08-07 11:59PM | | | |
| Duration: | 69 - Minutes | # of Customers: | 2 | Customer Minutes: 138 |
| Cause: | LIGHTNING | | | |
| Comments: | MAIN POINT LIGHTNING | | | |
| Interruption #: | 89924 | Outage Ticket: | | |
| Started: | 1999-08-09 10:15AM | | | |
| Ended: | 1999-08-09 01:30PM | | | |
| Duration: | 195 - Minutes | # of Customers: | 1 | Customer Minutes: 195 |
| Cause: | LIGHTNING | | | |
| Comments: | CARMANVILLE REPL TRF. | | | |
| Interruption #: | 90403 | Outage Ticket: | | |
| Started: | 1999-09-12 03:10PM | | | |
| Ended: | 1999-09-12 04:50PM | | | |
| Duration: | 100 - Minutes | # of Customers: | 5 | Customer Minutes: 500 |
| Cause: | ANIMALS (RODENTS ETC.) | | | |
| Comments: | CARMANVILLE REPL FUSE | | | |
| Interruption #: | 90574 | Outage Ticket: | | |
| Started: | 1999-09-23 02:14PM | | | |
| Ended: | 1999-09-23 02:50PM | | | |
| Duration: | 36 - Minutes | # of Customers: | 1 | Customer Minutes: 36 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | CARMANVILLE FAULTY FUSE | | | |
| Interruption #: | 90579 | Outage Ticket: | | |
| Started: | 1999-09-26 12:12PM | | | |
| Ended: | 1999-09-26 03:31PM | | | |
| Duration: | 199 - Minutes | # of Customers: | 1 | Customer Minutes: 199 |
| Cause: | DAMAGES OUTSIDE PARTY | | | |
| Comments: | CARMANVILLE BOAT HIT POWER SUPPLY @ WHARF | | | |
| Interruption #: | 91651 | Outage Ticket: | | |
| Started: | 1999-10-19 05:00AM | | | |
| Ended: | 1999-10-19 10:10AM | | | |
| Duration: | 310 - Minutes | # of Customers: | 837 | Customer Minutes: 259470 |
| Cause: | WIND | | | |
| Comments: | HEAVY WINDS & SNOW | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | |
|---------------------------|-----------------------------------|------------------------|---------------------|---------------------------------|
| Current Customers Served: | 879 | | | |
| Total Customers Affected: | 15224 | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | SAIDI: 41.15 | |
| Interruption #: | 91652 | Outage Ticket: | | |
| Started: | 1999-10-19 10:10AM | | | |
| Ended: | 1999-10-19 01:15PM | | | |
| Duration: | 185 - Minutes | # of Customers: | 70 | Customer Minutes: 12950 |
| Cause: | WIND | | | |
| Comments: | HEAVY WINDS & SNOW | | | |
| Interruption #: | 91653 | Outage Ticket: | | |
| Started: | 1999-10-19 01:15PM | | | |
| Ended: | 1999-10-19 01:25PM | | | |
| Duration: | 10 - Minutes | # of Customers: | 837 | Customer Minutes: 8370 |
| Cause: | WIND | | | |
| Comments: | HEAVY WINDS & SNOW | | | |
| Interruption #: | 91969 | Outage Ticket: | | |
| Started: | 1999-11-03 11:33AM | | | |
| Ended: | 1999-11-03 01:35PM | | | |
| Duration: | 122 - Minutes | # of Customers: | 4 | Customer Minutes: 488 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | NOGGIN COVE REPL FUSE IN 25KVA | | | |
| Interruption #: | 91973 | Outage Ticket: | | |
| Started: | 1999-11-07 03:24PM | | | |
| Ended: | 1999-11-07 05:30PM | | | |
| Duration: | 126 - Minutes | # of Customers: | 3 | Customer Minutes: 378 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | CARMANVILLE REPL. FUSE | | | |
| Interruption #: | 91974 | Outage Ticket: | | |
| Started: | 1999-11-12 10:53AM | | | |
| Ended: | 1999-11-12 12:40PM | | | |
| Duration: | 107 - Minutes | # of Customers: | 1 | Customer Minutes: 107 |
| Cause: | OTHER | | | |
| Comments: | CARMANVILLE | | | |
| Interruption #: | 92272 | Outage Ticket: | | |
| Started: | 1999-11-28 10:33AM | | | |
| Ended: | 1999-11-28 02:33PM | | | |
| Duration: | 240 - Minutes | # of Customers: | 837 | Customer Minutes: 200880 |
| Cause: | TREES IN LINE | | | |
| Comments: | CARMANVILLE TREE ON LINE | | | |
| Interruption #: | 92709 | Outage Ticket: | | |
| Started: | 1999-12-18 12:03PM | | | |
| Ended: | 1999-12-18 02:25PM | | | |
| Duration: | 142 - Minutes | # of Customers: | 837 | Customer Minutes: 118854 |
| Cause: | TREES IN LINE | | | |
| Comments: | GBY-02 R TRIPPED TREE ACROSS LINE | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

Current Customers Served: 879
Total Customers Affected: 15224
Total Customer Minutes: 2170310

SAIFI: 17.32
SAIDI: 41.15

Interruption #: 92710 **Outage Ticket:**
Started: 1999-12-18 02:25PM
Ended: 1999-12-18 02:32PM
Duration: 7 - Minutes **# of Customers:** 788 **Customer Minutes:** 5516
Cause: TREES IN LINE
Comments: GBY-02 R TRIPPED TREE ACROSS LINE

Interruption #: 92711 **Outage Ticket:**
Started: 1999-12-18 02:32PM
Ended: 1999-12-18 02:35PM
Duration: 3 - Minutes **# of Customers:** 837 **Customer Minutes:** 2511
Cause: TREES IN LINE
Comments: GBY-02 R TRIPPED TREE ACROSS LINE

Interruption #: 92712 **Outage Ticket:**
Started: 1999-12-18 02:35PM
Ended: 1999-12-18 03:30PM
Duration: 55 - Minutes **# of Customers:** 788 **Customer Minutes:** 43340
Cause: TREES IN LINE
Comments: GBY-02 R TRIPPED TREE ACROSS LINE

Interruption #: 92884 **Outage Ticket:**
Started: 1999-12-15 04:18PM
Ended: 1999-12-15 04:55PM
Duration: 37 - Minutes **# of Customers:** 2 **Customer Minutes:** 74
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: REPL FUSE IN CUTOUT

Interruption #: 92885 **Outage Ticket:**
Started: 1999-12-15 07:22PM
Ended: 1999-12-15 08:50PM
Duration: 88 - Minutes **# of Customers:** 3 **Customer Minutes:** 264
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: REPL FUSE IN CUTOUT

Interruption #: 93266 **Outage Ticket:**
Started: 2000-01-04 01:20AM
Ended: 2000-01-04 04:25AM
Duration: 185 - Minutes **# of Customers:** 1 **Customer Minutes:** 185
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: SERVICE BURNT OFF IN MIDSPAN - REPAIRED

Interruption #: 95533 **Outage Ticket:**
Started: 2000-05-13 08:26AM
Ended: 2000-05-13 11:16AM
Duration: 170 - Minutes **# of Customers:** 897 **Customer Minutes:** 152490
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: CONDUCTOR ON GROUND -- REINSTALLED IN POLE

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | | |
|---------------------------|---|------------------------|--------|--------------------------|-------|
| Current Customers Served: | 879 | | | | |
| Total Customers Affected: | 15224 | | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | | SAIDI: 41.15 | |
| Interruption #: | 96936 | Outage Ticket: | 108548 | | |
| Started: | 2000-07-11 09:05PM | | | | |
| Ended: | 2000-07-11 11:40PM | | | | |
| Duration: | 155 - Minutes | # of Customers: | 50 | Customer Minutes: | 7750 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | CARMANVILLE SOUTH REPL FAULTY CUTOFF IN SWITCH GBY-02-144 | | | | |
| Interruption #: | 97017 | Outage Ticket: | 108790 | | |
| Started: | 2000-07-16 04:21PM | | | | |
| Ended: | 2000-07-16 06:35PM | | | | |
| Duration: | 134 - Minutes | # of Customers: | 3 | Customer Minutes: | 402 |
| Cause: | UNEXPLAINED | | | | |
| Comments: | CARMANVILLE PHARMACY REFUSED TRANSFORMER | | | | |
| Interruption #: | 97122 | Outage Ticket: | 109068 | | |
| Started: | 2000-07-21 08:55AM | | | | |
| Ended: | 2000-07-21 04:16PM | | | | |
| Duration: | 441 - Minutes | # of Customers: | 50 | Customer Minutes: | 22050 |
| Cause: | DAMAGES OUTSIDE PARTY | | | | |
| Comments: | POLE REPLACED AND GBY-02-144 (CARMANVILLE SOUTH) CLOSED. | | | | |
| Interruption #: | 97230 | Outage Ticket: | 109125 | | |
| Started: | 2000-07-22 02:15PM | | | | |
| Ended: | 2000-07-22 02:40PM | | | | |
| Duration: | 25 - Minutes | # of Customers: | 1 | Customer Minutes: | 25 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | | | | | |
| Interruption #: | 97436 | Outage Ticket: | 109768 | | |
| Started: | 2000-08-05 09:35AM | | | | |
| Ended: | 2000-08-05 04:45PM | | | | |
| Duration: | 430 - Minutes | # of Customers: | 33 | Customer Minutes: | 14190 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | CONDUCTOR ON GROUND-FIRE | | | | |
| Interruption #: | 97537 | Outage Ticket: | 110191 | | |
| Started: | 2000-08-10 04:00PM | | | | |
| Ended: | 2000-08-10 04:54PM | | | | |
| Duration: | 54 - Minutes | # of Customers: | 897 | Customer Minutes: | 48438 |
| Cause: | PREVENTATIVE MAINTENANCE OR REPAIR | | | | |
| Comments: | REP INSUL | | | | |
| Interruption #: | 97698 | Outage Ticket: | 110699 | | |
| Started: | 2000-08-20 02:47PM | | | | |
| Ended: | 2000-08-20 05:20PM | | | | |
| Duration: | 153 - Minutes | # of Customers: | 5 | Customer Minutes: | 765 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | | | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | | |
|---------------------------|--|------------------------|--------|--------------------------|------|
| Current Customers Served: | 879 | | | | |
| Total Customers Affected: | 15224 | | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | | SAIDI: 41.15 | |
| Interruption #: | 97733 | Outage Ticket: | 110717 | | |
| Started: | 2000-08-21 07:00AM | | | | |
| Ended: | 2000-08-21 11:35AM | | | | |
| Duration: | 275 - Minutes | # of Customers: | 6 | Customer Minutes: | 1650 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | | | | | |
| Interruption #: | 98394 | Outage Ticket: | 112673 | | |
| Started: | 2000-09-21 01:45PM | | | | |
| Ended: | 2000-09-21 02:15PM | | | | |
| Duration: | 30 - Minutes | # of Customers: | 1 | Customer Minutes: | 30 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | REPL ALL CONN AT HSE | | | | |
| Interruption #: | 99236 | Outage Ticket: | 114691 | | |
| Started: | 2000-10-19 05:40PM | | | | |
| Ended: | 2000-10-19 06:40PM | | | | |
| Duration: | 60 - Minutes | # of Customers: | 1 | Customer Minutes: | 60 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | SERV DROP | | | | |
| Interruption #: | 101799 | Outage Ticket: | 125341 | | |
| Started: | 2001-01-02 02:10PM | | | | |
| Ended: | 2001-01-02 06:45PM | | | | |
| Duration: | 275 - Minutes | # of Customers: | 4 | Customer Minutes: | 1100 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | REPLACED SERVICE WIRES AND CONNECTIONS ON SECONDARY. | | | | |
| Interruption #: | 101876 | Outage Ticket: | 125638 | | |
| Started: | 2001-01-05 02:55PM | | | | |
| Ended: | 2001-01-05 03:05PM | | | | |
| Duration: | 10 - Minutes | # of Customers: | 1 | Customer Minutes: | 10 |
| Cause: | FIRE | | | | |
| Comments: | DISC AND REM SERV | | | | |
| Interruption #: | 101886 | Outage Ticket: | 125660 | | |
| Started: | 2001-01-05 04:15PM | | | | |
| Ended: | 2001-01-05 07:15PM | | | | |
| Duration: | 180 - Minutes | # of Customers: | 3 | Customer Minutes: | 540 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | REPLACED SECONDARY LEADS IN 15 KVA XFMR 3 CUSTOMERS. | | | | |
| Interruption #: | 101926 | Outage Ticket: | 125909 | | |
| Started: | 2001-01-09 03:55PM | | | | |
| Ended: | 2001-01-09 05:30PM | | | | |
| Duration: | 95 - Minutes | # of Customers: | 60 | Customer Minutes: | 5700 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | | |
| Comments: | REPLACED FUSE | | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | |
|---------------------------|--|------------------------|------------------------------------|
| Current Customers Served: | 879 | | |
| Total Customers Affected: | 15224 | SAIFI: | 17.32 |
| Total Customer Minutes: | 2170310 | SAIDI: | 41.15 |
| Interruption #: | 101946 | Outage Ticket: | 126061 |
| Started: | 2001-01-11 10:30AM | | |
| Ended: | 2001-01-11 10:45AM | | |
| Duration: | 15 - Minutes | # of Customers: | 1 Customer Minutes: 15 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPL CONN AT POLE | | |
| Interruption #: | 102327 | Outage Ticket: | 127669 |
| Started: | 2001-01-30 11:19AM | | |
| Ended: | 2001-01-30 11:40AM | | |
| Duration: | 21 - Minutes | # of Customers: | 897 Customer Minutes: 18837 |
| Cause: | EMPLOYEE OPERATING ERROR | | |
| Comments: | FEEDER LOCKED OUT | | |
| Interruption #: | 102332 | Outage Ticket: | 127706 |
| Started: | 2001-01-30 01:40PM | | |
| Ended: | 2001-01-30 02:00PM | | |
| Duration: | 20 - Minutes | # of Customers: | 2 Customer Minutes: 40 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPAIRED MAIN NEUTRAL | | |
| Interruption #: | 102898 | Outage Ticket: | 130316 |
| Started: | 2001-02-22 06:13AM | | |
| Ended: | 2001-02-22 11:57AM | | |
| Duration: | 344 - Minutes | # of Customers: | 140 Customer Minutes: 48160 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPLACED INS BEYOND DISCONNECT 230 | | |
| Interruption #: | 104610 | Outage Ticket: | 136896 |
| Started: | 2001-05-14 04:25PM | | |
| Ended: | 2001-05-14 04:35PM | | |
| Duration: | 10 - Minutes | # of Customers: | 1 Customer Minutes: 10 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | CHANGED CONNECTIONS AT HOUSE | | |
| Interruption #: | 104670 | Outage Ticket: | 137085 |
| Started: | 2001-05-17 03:00PM | | |
| Ended: | 2001-05-17 03:25PM | | |
| Duration: | 25 - Minutes | # of Customers: | 1 Customer Minutes: 25 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | ERN COLLINS NOGGIN CV REPLACED ALL CONNECTIONS | | |
| Interruption #: | 104698 | Outage Ticket: | 137156 |
| Started: | 2001-05-18 09:30PM | | |
| Ended: | 2001-05-19 12:05AM | | |
| Duration: | 155 - Minutes | # of Customers: | 1 Customer Minutes: 155 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | CARMANVILLE REPLACED FUSE IN XMFR | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | |
|---------------------------|--|------------------------|---------------------|--------------------------------|
| Current Customers Served: | 879 | | | |
| Total Customers Affected: | 15224 | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | SAIDI: 41.15 | |
| Interruption #: | 105075 | Outage Ticket: | 138384 | |
| Started: | 2001-06-12 07:50PM | | | |
| Ended: | 2001-06-12 09:25PM | | | |
| Duration: | 95 - Minutes | # of Customers: | 267 | Customer Minutes: 25365 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACE BROKEN POLE-RTTED OFF AT BASE | | | |
| Interruption #: | 105418 | Outage Ticket: | 139548 | |
| Started: | 2001-07-06 08:28AM | | | |
| Ended: | 2001-07-06 10:10AM | | | |
| Duration: | 102 - Minutes | # of Customers: | 6 | Customer Minutes: 612 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED CUTOUT AND XMFR FUSE | | | |
| Interruption #: | 105459 | Outage Ticket: | 139638 | |
| Started: | 2001-07-08 07:40PM | | | |
| Ended: | 2001-07-08 10:05PM | | | |
| Duration: | 145 - Minutes | # of Customers: | 1 | Customer Minutes: 145 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED 1 AMP FUSE IN 10KVA XFMR. 1 CUSTOMER. | | | |
| Interruption #: | 105462 | Outage Ticket: | 139646 | |
| Started: | 2001-07-09 09:35AM | | | |
| Ended: | 2001-07-09 11:55AM | | | |
| Duration: | 140 - Minutes | # of Customers: | 4 | Customer Minutes: 560 |
| Cause: | BIRDS | | | |
| Comments: | REPLACED A 6 AMP IN A 50 KVA | | | |
| Interruption #: | 106128 | Outage Ticket: | 141892 | |
| Started: | 2001-08-15 07:30PM | | | |
| Ended: | 2001-08-15 07:45PM | | | |
| Duration: | 15 - Minutes | # of Customers: | 1 | Customer Minutes: 15 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | CHANGED ALL CONN AT HOUSE | | | |
| Interruption #: | 106362 | Outage Ticket: | 142518 | |
| Started: | 2001-08-24 11:15PM | | | |
| Ended: | 2001-08-24 11:25PM | | | |
| Duration: | 10 - Minutes | # of Customers: | 7 | Customer Minutes: 70 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPAIRED SPADE TERMINAL | | | |
| Interruption #: | 107676 | Outage Ticket: | 146589 | |
| Started: | 2001-10-15 09:54PM | | | |
| Ended: | 2001-10-15 11:59PM | | | |
| Duration: | 125 - Minutes | # of Customers: | 5 | Customer Minutes: 625 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED A2 AMP IN A 25 KVA | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | |
|---------------------------|---------------------------------------|------------------------|---------------------|---------------------------------|
| Current Customers Served: | 879 | | | |
| Total Customers Affected: | 15224 | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | SAIDI: 41.15 | |
| Interruption #: | 107683 | Outage Ticket: | 146594 | |
| Started: | 2001-10-16 10:00AM | | | |
| Ended: | 2001-10-16 12:50PM | | | |
| Duration: | 170 - Minutes | # of Customers: | 6 | Customer Minutes: 1020 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED FAULTY XMFR | | | |
| Interruption #: | 107690 | Outage Ticket: | 146666 | |
| Started: | 2001-10-16 07:54PM | | | |
| Ended: | 2001-10-16 10:00PM | | | |
| Duration: | 126 - Minutes | # of Customers: | 6 | Customer Minutes: 756 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACE BROKEN CUTOUT | | | |
| Interruption #: | 108898 | Outage Ticket: | 150517 | |
| Started: | 2001-11-29 08:14PM | | | |
| Ended: | 2001-11-29 08:29PM | | | |
| Duration: | 15 - Minutes | # of Customers: | 1 | Customer Minutes: 15 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED ALL CONNECTIONS AT THE HOUSE | | | |
| Interruption #: | 110524 | Outage Ticket: | 155581 | |
| Started: | 2002-01-31 10:30AM | | | |
| Ended: | 2002-01-31 11:30AM | | | |
| Duration: | 60 - Minutes | # of Customers: | 1 | Customer Minutes: 60 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED CONN AT POLE | | | |
| Interruption #: | 110843 | Outage Ticket: | 156586 | |
| Started: | 2002-02-11 01:12PM | | | |
| Ended: | 2002-02-11 03:09PM | | | |
| Duration: | 117 - Minutes | # of Customers: | 888 | Customer Minutes: 103896 |
| Cause: | WIND | | | |
| Comments: | REPLACED INSULATOR AND PIN | | | |
| Interruption #: | 110983 | Outage Ticket: | 157066 | |
| Started: | 2002-02-13 10:22PM | | | |
| Ended: | 2002-02-14 12:30AM | | | |
| Duration: | 128 - Minutes | # of Customers: | 420 | Customer Minutes: 53760 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED INSULATOR | | | |
| Interruption #: | 110984 | Outage Ticket: | 157066 | |
| Started: | 2002-02-13 10:22PM | | | |
| Ended: | 2002-02-14 01:40AM | | | |
| Duration: | 198 - Minutes | # of Customers: | 75 | Customer Minutes: 14850 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED INSULATOR | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | |
|---------------------------|--|------------------------|------------------------------------|
| Current Customers Served: | 879 | | |
| Total Customers Affected: | 15224 | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | SAIDI: 41.15 | |
| Interruption #: | 111226 | Outage Ticket: | 157778 |
| Started: | 2002-02-23 08:01PM | | |
| Ended: | 2002-02-23 11:40PM | | |
| Duration: | 219 - Minutes | # of Customers: | 1 Customer Minutes: 219 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPLACED ALL SERVICE CONNECTIONS AT POLE AND HOUSE. | | |
| Interruption #: | 111888 | Outage Ticket: | 159917 |
| Started: | 2002-03-23 02:18AM | | |
| Ended: | 2002-03-23 05:45AM | | |
| Duration: | 207 - Minutes | # of Customers: | 100 Customer Minutes: 20700 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | RETIE FLOATING PHASE. | | |
| Interruption #: | 112071 | Outage Ticket: | 160285 |
| Started: | 2002-03-28 01:25PM | | |
| Ended: | 2002-03-28 01:45PM | | |
| Duration: | 20 - Minutes | # of Customers: | 1 Customer Minutes: 20 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPLACED CONNECTIONS AT THE WEATHERHEAD. | | |
| Interruption #: | 112362 | Outage Ticket: | 161402 |
| Started: | 2002-04-13 05:32PM | | |
| Ended: | 2002-04-13 08:30PM | | |
| Duration: | 178 - Minutes | # of Customers: | 100 Customer Minutes: 17800 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | CUTOUT REPLACED | | |
| Interruption #: | 113565 | Outage Ticket: | 164237 |
| Started: | 2002-06-01 12:40PM | | |
| Ended: | 2002-06-01 12:50PM | | |
| Duration: | 10 - Minutes | # of Customers: | 1 Customer Minutes: 10 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPLACED CONNECTIONS | | |
| Interruption #: | 113940 | Outage Ticket: | 165323 |
| Started: | 2002-06-24 11:43PM | | |
| Ended: | 2002-06-25 03:50AM | | |
| Duration: | 247 - Minutes | # of Customers: | 1 Customer Minutes: 247 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPL 25 WITH 10 KVA | | |
| Interruption #: | 114248 | Outage Ticket: | 166186 |
| Started: | 2002-07-02 10:00AM | | |
| Ended: | 2002-07-02 10:25AM | | |
| Duration: | 25 - Minutes | # of Customers: | 5 Customer Minutes: 125 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPLACED 6AMP FUSE IN 50KVA & 8AMP FUSE IN GBY-02 F126 | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | |
|---------------------------|--|------------------------|----------------------------------|
| Current Customers Served: | 879 | | |
| Total Customers Affected: | 15224 | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | SAIDI: 41.15 | |
| Interruption #: | 114250 | Outage Ticket: | 166164 |
| Started: | 2002-07-02 11:00AM | | |
| Ended: | 2002-07-02 11:35AM | | |
| Duration: | 35 - Minutes | # of Customers: | 1 Customer Minutes: 35 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPLACED CONN @ POLE & MAST | | |
| Interruption #: | 114826 | Outage Ticket: | 167666 |
| Started: | 2002-07-24 09:22AM | | |
| Ended: | 2002-07-24 01:00PM | | |
| Duration: | 218 - Minutes | # of Customers: | 4 Customer Minutes: 872 |
| Cause: | BIRDS | | |
| Comments: | FUSE BLOWN DUE TO CROW | | |
| Interruption #: | 114893 | Outage Ticket: | 167830 |
| Started: | 2002-07-26 10:10AM | | |
| Ended: | 2002-07-26 10:45AM | | |
| Duration: | 35 - Minutes | # of Customers: | 10 Customer Minutes: 350 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPLACED 20 AMP FUSE IN TAP MAIN POINT | | |
| Interruption #: | 115783 | Outage Ticket: | 171419 |
| Started: | 2002-08-20 05:35AM | | |
| Ended: | 2002-08-20 07:00AM | | |
| Duration: | 85 - Minutes | # of Customers: | 20 Customer Minutes: 1700 |
| Cause: | LIGHTNING | | |
| Comments: | REPLACED FUSE IN XMFR | | |
| Interruption #: | 115992 | Outage Ticket: | 171786 |
| Started: | 2002-08-22 04:27PM | | |
| Ended: | 2002-08-22 06:55PM | | |
| Duration: | 148 - Minutes | # of Customers: | 3 Customer Minutes: 444 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPLACE CUTOFF ON XFMR | | |
| Interruption #: | 116456 | Outage Ticket: | 173036 |
| Started: | 2002-09-11 07:45AM | | |
| Ended: | 2002-09-11 10:45AM | | |
| Duration: | 180 - Minutes | # of Customers: | 7 Customer Minutes: 1260 |
| Cause: | BIRDS | | |
| Comments: | REPLACED XMFR FUSE | | |
| Interruption #: | 116841 | Outage Ticket: | 174799 |
| Started: | 2002-09-26 03:38PM | | |
| Ended: | 2002-09-26 05:20PM | | |
| Duration: | 102 - Minutes | # of Customers: | 2 Customer Minutes: 204 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | |
| Comments: | REPLACED A 2 AMP IN A 10 KVA | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | |
|---------------------------|---|------------------------|---------------------|---------------------------------|
| Current Customers Served: | 879 | | | |
| Total Customers Affected: | 15224 | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | SAIDI: 41.15 | |
| Interruption #: | 117261 | Outage Ticket: | 176452 | |
| Started: | 2002-10-22 05:01PM | | | |
| Ended: | 2002-10-22 08:30PM | | | |
| Duration: | 209 - Minutes | # of Customers: | 1 | Customer Minutes: 209 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPL SERVICE | | | |
| Interruption #: | 117269 | Outage Ticket: | 176453 | |
| Started: | 2002-10-23 01:30PM | | | |
| Ended: | 2002-10-23 02:30PM | | | |
| Duration: | 60 - Minutes | # of Customers: | 1 | Customer Minutes: 60 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED SERV CONNECTIONS | | | |
| Interruption #: | 117272 | Outage Ticket: | 176535 | |
| Started: | 2002-10-23 09:35PM | | | |
| Ended: | 2002-10-23 09:45PM | | | |
| Duration: | 10 - Minutes | # of Customers: | 1 | Customer Minutes: 10 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED CONNECTIONS AT SERVICE POLE | | | |
| Interruption #: | 117398 | Outage Ticket: | 177003 | |
| Started: | 2002-10-29 11:30AM | | | |
| Ended: | 2002-10-29 12:30PM | | | |
| Duration: | 60 - Minutes | # of Customers: | 1 | Customer Minutes: 60 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED SERV CONNECTIONS | | | |
| Interruption #: | 117498 | Outage Ticket: | 177418 | |
| Started: | 2002-11-04 10:30AM | | | |
| Ended: | 2002-11-04 11:20AM | | | |
| Duration: | 50 - Minutes | # of Customers: | 1 | Customer Minutes: 50 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED SERV CONNECTIONS | | | |
| Interruption #: | 117531 | Outage Ticket: | 177603 | |
| Started: | 2002-11-06 07:39AM | | | |
| Ended: | 2002-11-06 11:08AM | | | |
| Duration: | 209 - Minutes | # of Customers: | 888 | Customer Minutes: 185592 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | PRIMARY ON GROUND ON GBY-02/INSULATORS SHOT OFF ON GBY-03 | | | |
| Interruption #: | 117578 | Outage Ticket: | 177877 | |
| Started: | 2002-11-10 05:43PM | | | |
| Ended: | 2002-11-10 08:30PM | | | |
| Duration: | 167 - Minutes | # of Customers: | 1 | Customer Minutes: 167 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | CHANGED ALL CONN AT POLE AND HOUSE | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

Current Customers Served: 879
Total Customers Affected: 15224
Total Customer Minutes: 2170310

SAIFI: 17.32
SAIDI: 41.15

Interruption #: 117619 **Outage Ticket:** 169809
Started: 2002-08-14 06:08PM
Ended: 2002-08-14 07:00PM
Duration: 52 - Minutes **# of Customers:** 3 **Customer Minutes:** 156
Cause: LIGHTNING
Comments:

Interruption #: 117680 **Outage Ticket:** 178233
Started: 2002-11-15 08:57AM
Ended: 2002-11-15 10:22AM
Duration: 85 - Minutes **# of Customers:** 12 **Customer Minutes:** 1020
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: REPLACED FUSE IN XMFR

Interruption #: 117699 **Outage Ticket:** 178325
Started: 2002-11-15 06:42PM
Ended: 2002-11-15 10:00PM
Duration: 198 - Minutes **# of Customers:** 8 **Customer Minutes:** 1584
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: REPL 37 WITH A 50

Interruption #: 117818 **Outage Ticket:** 178684
Started: 2002-11-20 12:57PM
Ended: 2002-11-20 03:00PM
Duration: 123 - Minutes **# of Customers:** 10 **Customer Minutes:** 1230
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: REPLACED XMFR FUSE

Interruption #: 118585 **Outage Ticket:** 180820
Started: 2002-12-18 06:30AM
Ended: 2002-12-18 09:37AM
Duration: 187 - Minutes **# of Customers:** 8 **Customer Minutes:** 1496
Cause: SALT SPRAY
Comments: REPLACED TAP FUSE

Interruption #: 118587 **Outage Ticket:** 180825
Started: 2002-12-18 08:39AM
Ended: 2002-12-18 10:30AM
Duration: 111 - Minutes **# of Customers:** 80 **Customer Minutes:** 8880
Cause: SALT SPRAY
Comments: REPLACED TAP FUSE

Interruption #: 118869 **Outage Ticket:** 181389
Started: 2002-12-27 10:30AM
Ended: 2002-12-27 05:54PM
Duration: 444 - Minutes **# of Customers:** 40 **Customer Minutes:** 17760
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: REPAIRED PHASE

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

Current Customers Served: 879
Total Customers Affected: 15224
Total Customer Minutes: 2170310

SAIFI: 17.32
SAIDI: 41.15

Interruption #: 118872 **Outage Ticket:** 181799
Started: 2002-12-27 03:00PM
Ended: 2002-12-27 06:00PM
Duration: 180 - Minutes **# of Customers:** 12 **Customer Minutes:** 2160
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: REPLACE FUSE

Interruption #: 118954 **Outage Ticket:** 181579
Started: 2002-12-27 03:51PM
Ended: 2002-12-27 06:00PM
Duration: 129 - Minutes **# of Customers:** 150 **Customer Minutes:** 19350
Cause: WIND
Comments:

Interruption #: 118979 **Outage Ticket:** 181773
Started: 2002-12-27 06:18PM
Ended: 2002-12-28 01:00PM
Duration: 1122 - Minutes **# of Customers:** 12 **Customer Minutes:** 13464
Cause: WIND
Comments:

Interruption #: 118982 **Outage Ticket:** 182012
Started: 2002-12-28 09:36AM
Ended: 2002-12-28 11:45AM
Duration: 129 - Minutes **# of Customers:** 80 **Customer Minutes:** 10320
Cause: WIND
Comments:

Interruption #: 119035 **Outage Ticket:** 182376
Started: 2002-12-31 12:41PM
Ended: 2003-01-01 12:40PM
Duration: 1439 - Minutes **# of Customers:** 1 **Customer Minutes:** 1439
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: REPLACED A CUTOUT

Interruption #: 119036 **Outage Ticket:** 182460
Started: 2003-01-01 09:11AM
Ended: 2003-01-01 11:50AM
Duration: 159 - Minutes **# of Customers:** 8 **Customer Minutes:** 1272
Cause: BROKEN OR DEFECTIVE EQUIPMENT
Comments: REPLACED A CUTOUT

Interruption #: 119453 **Outage Ticket:** 184017
Started: 2003-01-20 11:20AM
Ended: 2003-01-20 02:15PM
Duration: 175 - Minutes **# of Customers:** 1 **Customer Minutes:** 175
Cause: SALT SPRAY
Comments: REPL XMFR FUSE

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | |
|---------------------------|---|------------------------|---------------------|--------------------------------|
| Current Customers Served: | 879 | | | |
| Total Customers Affected: | 15224 | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | SAIDI: 41.15 | |
| Interruption #: | 120717 | Outage Ticket: | 187834 | |
| Started: | 2003-02-14 01:50PM | | | |
| Ended: | 2003-02-14 02:30PM | | | |
| Duration: | 40 - Minutes | # of Customers: | 180 | Customer Minutes: 7200 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REFUSED TAP | | | |
| Interruption #: | 120721 | Outage Ticket: | 187867 | |
| Started: | 2003-02-14 03:50PM | | | |
| Ended: | 2003-02-14 11:38PM | | | |
| Duration: | 468 - Minutes | # of Customers: | 5 | Customer Minutes: 2340 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED XMFR | | | |
| Interruption #: | 121545 | Outage Ticket: | 191066 | |
| Started: | 2003-03-09 01:23PM | | | |
| Ended: | 2003-03-09 03:50PM | | | |
| Duration: | 147 - Minutes | # of Customers: | 1 | Customer Minutes: 147 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED CUTOUT AT RITEWAY IN CARMANVILLE | | | |
| Interruption #: | 122487 | Outage Ticket: | 193711 | |
| Started: | 2003-04-18 08:37AM | | | |
| Ended: | 2003-04-18 10:55AM | | | |
| Duration: | 138 - Minutes | # of Customers: | 75 | Customer Minutes: 10350 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | RE-FUSED F124 | | | |
| Interruption #: | 122789 | Outage Ticket: | 194412 | |
| Started: | 2003-05-01 09:40PM | | | |
| Ended: | 2003-05-01 10:10PM | | | |
| Duration: | 30 - Minutes | # of Customers: | 1 | Customer Minutes: 30 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED CONNECTIONS | | | |
| Interruption #: | 122812 | Outage Ticket: | 194466 | |
| Started: | 2003-05-03 01:00PM | | | |
| Ended: | 2003-05-03 03:10PM | | | |
| Duration: | 130 - Minutes | # of Customers: | 6 | Customer Minutes: 780 |
| Cause: | BIRDS | | | |
| Comments: | RE-FUSED TAP AND XFMR | | | |
| Interruption #: | 124057 | Outage Ticket: | 197478 | |
| Started: | 2003-06-27 03:08PM | | | |
| Ended: | 2003-06-27 05:45PM | | | |
| Duration: | 157 - Minutes | # of Customers: | 100 | Customer Minutes: 15700 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPAIRED N/CONDUCTOR | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | | | |
|---------------------------|---|------------------------|---------------------|---------------------------------|
| Current Customers Served: | 879 | | | |
| Total Customers Affected: | 15224 | | SAIFI: 17.32 | |
| Total Customer Minutes: | 2170310 | | SAIDI: 41.15 | |
| Interruption #: | 124215 | Outage Ticket: | 197881 | |
| Started: | 2003-07-06 01:12AM | | | |
| Ended: | 2003-07-06 07:50AM | | | |
| Duration: | 398 - Minutes | # of Customers: | 1 | Customer Minutes: 398 |
| Cause: | LIGHTNING | | | |
| Comments: | REPLACED FUSE IN XMFR | | | |
| Interruption #: | 124422 | Outage Ticket: | 198568 | |
| Started: | 2003-07-16 03:35PM | | | |
| Ended: | 2003-07-16 04:00PM | | | |
| Duration: | 25 - Minutes | # of Customers: | 101 | Customer Minutes: 2525 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | GBY-02-F124 OPENED TO REPLACE BROKEN XFMR CUTOUT AT DAVIDSVILLE | | | |
| Interruption #: | 125711 | Outage Ticket: | 202751 | |
| Started: | 2003-09-06 08:32AM | | | |
| Ended: | 2003-09-06 10:25AM | | | |
| Duration: | 113 - Minutes | # of Customers: | 3 | Customer Minutes: 339 |
| Cause: | DAMAGES OUTSIDE PARTY | | | |
| Comments: | CLOSED FUSE AFTER CAR HIT POLE | | | |
| Interruption #: | 126279 | Outage Ticket: | 204596 | |
| Started: | 2003-10-03 02:40AM | | | |
| Ended: | 2003-10-03 03:25AM | | | |
| Duration: | 45 - Minutes | # of Customers: | 150 | Customer Minutes: 6750 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | GBY-02-F144 OPENED TO REPLACE FAULTY INSULATOR | | | |
| Interruption #: | 126320 | Outage Ticket: | 204712 | |
| Started: | 2003-10-05 11:28AM | | | |
| Ended: | 2003-10-05 02:30PM | | | |
| Duration: | 182 - Minutes | # of Customers: | 6 | Customer Minutes: 1092 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPLACED CUTOUT DOOR | | | |
| Interruption #: | 126366 | Outage Ticket: | 204728 | |
| Started: | 2003-10-05 10:05PM | | | |
| Ended: | 2003-10-06 02:00AM | | | |
| Duration: | 235 - Minutes | # of Customers: | 46 | Customer Minutes: 10810 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | PRIMARY DOWN | | | |
| Interruption #: | 126367 | Outage Ticket: | 204728 | |
| Started: | 2003-10-05 10:05PM | | | |
| Ended: | 2003-10-06 10:40AM | | | |
| Duration: | 755 - Minutes | # of Customers: | 167 | Customer Minutes: 126085 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | PRIMARY DOWN | | | |

Newfoundland Power
Interruption Details - Unscheduled NP Distribution
Feeder: GBY-02 1999-01-01 to 2003-12-31

| | | |
|---------------------------|---------|---------------------|
| Current Customers Served: | 879 | |
| Total Customers Affected: | 15224 | SAIFI: 17.32 |
| Total Customer Minutes: | 2170310 | SAIDI: 41.15 |

| | | | | |
|------------------------|-------------------------------|------------------------|--------|---------------------------------|
| Interruption #: | 126368 | Outage Ticket: | 204728 | |
| Started: | 2003-10-05 10:05PM | | | |
| Ended: | 2003-10-06 01:24AM | | | |
| Duration: | 199 - Minutes | # of Customers: | 673 | Customer Minutes: 133927 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | PRIMARY DOWN | | | |

| | | | | |
|------------------------|-------------------------------|------------------------|--------|---------------------------------|
| Interruption #: | 126369 | Outage Ticket: | 204728 | |
| Started: | 2003-10-06 02:30AM | | | |
| Ended: | 2003-10-06 10:40AM | | | |
| Duration: | 490 - Minutes | # of Customers: | 673 | Customer Minutes: 329770 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | PRIMARY DOWN | | | |

| | | | | |
|------------------------|-------------------------------|------------------------|--------|-----------------------------|
| Interruption #: | 126410 | Outage Ticket: | 205024 | |
| Started: | 2003-10-09 01:10PM | | | |
| Ended: | 2003-10-09 01:40PM | | | |
| Duration: | 30 - Minutes | # of Customers: | 1 | Customer Minutes: 30 |
| Cause: | BROKEN OR DEFECTIVE EQUIPMENT | | | |
| Comments: | REPL SERV CONN | | | |
