

Q. ENERGY SUPPLY**PUB 2.0 (RE: p. 12 & 13 of 73) Wesleyville Gas Turbine Overhaul (\$1,124,000)****PUB 2.3**

Over the three year period from 1999 to 2001, on an annual basis, how many times and for how many hours has this unit been placed in operation? On an annual basis how many kWh have been produced by this unit?

- A. The table below provides a summary for 1999 to 2001 of the number of times the gas turbine generator was started, the number of hours the unit was run, and the amount of energy produced by the unit, which was then located at Salt Pond.

The operating statistics include only instances where the unit was placed in operation and generated kWhs. It does not include the instances where the unit was started for testing and maintenance purposes, but no kWhs were produced.

Newfoundland Power Inc. Wesleyville Gas Turbine Operating Statistics 1999 - 2001			
Year	Starts	Run Time (hours)	Production (kWh)
1999	12	10.9	100,200
2000	13	12.1	69,730
2001	10	6.7	49,400