

1 **Q. ENERGY SUPPLY**

2
3 **PUB 3.0 (RE: p. 14, 15 & 16 of 73) Rattling Brook – Hydro Plant Refurbishment**
4 **(\$350,000)**

5
6 **PUB 3.1**

7 **The report undertaken by SGE Acres and provided in Appendix 3, Attachment B,**
8 **Recommendations (3.3, 2, 7, and 3.4) indicates that several repairs are not urgent.**
9 **Is it the intention of NP to include these repairs in this project? If so, why?**

10
11 **A.** It is Newfoundland Power's intention to include these repairs in this project. The SGE
12 Acres report was completed in 2003.

13
14 The recommendation in item 2, Section 3.3, indicates that the repairs should be
15 undertaken as early as practical, and the repair will be undertaken in 2007.

16
17 The recommendations in item 7, Section 3.3, and in Section 3.4 are that replacement of
18 these components should be undertaken within the next 5 years. This work is scheduled
19 for 2007, which will provide for completion 4 years from the time the consultant's
20 recommendations were made.