

1 **Q. SUBSTATIONS**

2
3 **PUB 4.0 (RE: p. 17 & 18 of 73) Rebuild Substations (\$351,000)**

4
5 **PUB 4.1**

6 **What are the ages of the existing weather enclosures at St. John's?**

7
8 A. There are three metal clad switchgear enclosures at St. John's Main Substation. These
9 enclosures are 21, 26 and 27 years old, respectively.