

1 **Q. TRANSMISSION**

2  
3 **PUB 40.0 (RE: B-29, Rebuild Transmission Lines)**

4  
5 **PUB 40.2**

6 **Does the Company have a target a level of reliability, measured as SAIFI and**  
7 **SAIDI, for its Transmission lines?**

8  
9 A. The Company does not have a reliability target for Transmission Lines. The Company  
10 has established overall SAIFI and SAIDI reliability targets. To meet the targets requires  
11 the Company to maintain and where necessary improve the reliability of all elements of  
12 the power system including the distribution system, transmission system and generation  
13 system.