

1 **Q. SUBSTATIONS**

2
3 **PUB 8.0 (RE: p. 27 & 28 of 73) Feeder Additions due to Load Growth and**
4 **Reliability (\$268,000)**

5
6 **PUB 8.1**

7 **In Distribution, Appendix 2, Attachment 2, the construction of the new feeder VIR-**
8 **08 in Alternative #1 is described as a 12.5 kV feeder, while the feeder described on**
9 **p. 27 of 73 is described as a 25 kV feeder. Please verify the size of the feeder being**
10 **constructed.**

11
12 A. The new feeder to be constructed at Virginia Waters Substation has a voltage rating of
13 12.5 kV, as do all the existing feeders at Virginia Waters Substation. The reference to a
14 25 kV feeder on page 27 of 73 in Schedule B is in error, and will be revised to correct the
15 reference.