

**Q. TRANSMISSION****PUB 9.0 (RE: p. 29 & 30 of 73) Rebuild Transmission Lines (\$2,597,000)****PUB 9.2****Please provide for each year from 2000 to 2004F inclusive the total expenditure for each of transmission lines 11L, 43L and 124L.**

- A. The table below provides a summary of the total capital expenditures for each of transmission lines 11L, 43L, and 124L for the period 2000 to 2004F inclusive.

<b>Newfoundland Power Inc.</b> <b>Total Expenditures for 11L, 43L and 124L</b> <b>2000 - 2004F</b> <b>(\$000s)</b>					
	<b>2000</b>	<b>2001</b>	<b>2002</b>	<b>2003</b>	<b>2004F</b>
11L	9	1	15	1	-
43L	-	85	6	7	2
124L	15	361	57	472	3

Transmission line 124L is one of the Company's longer transmission lines extending 90 km from Clarenville to Gambo. Rebuilds on 124L are normally done in sections, as was the case in 2001 and 2003 when rebuilds were conducted on a 5.2 km and a 5.5 km section, respectively. The expenditures for these rebuilds which are outlined in Volume II, Transmission, Appendix 1 are included in the totals for 124L in the table above. The rebuild budgeted for 2005 is for a 5 km section of the line just west of Clarenville.