

Q. DISTRIBUTION**DISTRIBUTION RELIABILITY INITIATIVE (POOLED), p. 45 of 81, \$3,114,000****PUB 19.0****Given that a 12/6 km. section of feeder GLV-02 was upgraded in 2003 and 2004, excluding this section what are the SAIFI and SAIDI statistics for the period from 2000 to 2004?**

- A. Table 1 below shows the unscheduled distribution SAIDI and SAIFI statistics for the period 2000 to 2004 for the GLV-02 feeder, excluding the sections upgraded in 2003 and 2004.

Table 1		
Select SAIDI and SAIFI Statistics for GLV-02 Unscheduled Distribution Outages 2000-2004 ¹		
Year	SAIDI	SAIFI
2000	0.17	0.19
2001	1.80	1.95
2002	0.23	0.13
2003	12.00	4.23
2004	5.98	4.31

¹ Excluding the sections of GLV-02 that were upgraded in 2003 and 2004.