
1 Q. **Project C-8: Water System Replacements, Bay d’Espoir and Cat Arm**

2 With reference to page 15, Development of Alternatives, Replace Existing Piping
3 with Corrosion Resistant Piping, please provide further details with respect to the
4 potential frequency and cost of future maintenance costs of cleaning the piping
5 every year because of fouling.

6

7

8 A. Hydro is not proposing or recommending cleaning the pipes every year as this form
9 of maintenance has been used by Hydro in the past and was found to cause
10 damages to the piping. As such, Hydro has not determined the cost of cleaning the
11 piping every year.