

1 **Q. Please advise if Newfoundland and Labrador Hydro (“Hydro”) is also equipped**  
2 **with MGTs or similar and, if so, how many and where these are located.**  
3

4 A. Hydro does not have a mobile gas turbine, or other mobile generation equipment of  
5 similar size, that operates at distribution-level voltages.  
6

7 It is Newfoundland Power’s understanding that Hydro has a 255 kilowatt mobile diesel  
8 generator stationed at Bishop Falls to support their distribution systems on the Island. In  
9 Southern Labrador, Hydro has a 600 kilowatt mobile diesel generator to support their  
10 isolated systems. The location of this unit is not fixed; it is stationed at various locations  
11 based on Hydro’s operational requirements. Confirmation of this information should be  
12 sought from Hydro.