

1 Q. Re: 2013 Capital Projects 500,000 and Over: p. C-62 Replace MDR4000 Microwave
2 Radio (West):

3 What was the anticipated life of this radio system when it was installed in 1999?

4

5

6 A. The anticipated life of this radio system when it was installed in 1999 was ten years.

7 Note that the justification for the replacement of this equipment is not based on

8 exceeding the anticipated life in 1999. Rather, it is justified on the equipment being

9 discontinued and the lack of available vendor support and spares as detailed in the

10 report.