

- 1 Q. Re: 2013 Capital Projects 200,000 and Over but less than 500,000:
2 Explanations, pages D-123 through D-132 Replace Disconnects:
3 Does Hydro have data as to how many operations its current disconnect switches
4 have had?
5
6
7 A. No, Hydro does not track the number of operations its current disconnect switches
8 have experienced.