

1 Q. Re: 2013 Capital Projects Over 200,000 but less than 500,000: p. D-210

2 Install Additional Washrooms (Various Sites):

3 Reference the consultations referred to at p. 213, please provide copies of all  
4 communications, memos, notes and minutes pertaining to the same.

5

6

7 A. The consultations referred to on page D-213 pertain to a phone conversation held  
8 with an enforcement official of the Provincial OHSA Regulations on June 28, 2012.

9 The remote nature and infrequent usage of Hydro's site facilities was explained and  
10 the question posed as to whether or not any allowances for structures of this  
11 nature would be considered under the regulations. The enforcement officials'  
12 interpretation of the OHSA Regulations indicated that no allowance would be  
13 granted and that if male and female workers are expected to conduct work at the  
14 facility then separate washrooms are required.