

1 Q. Re: 2013 Capital Projects 200,000 and Over but less than 500,000:
2 Explanations, pages D-245 through D-254 Replace Radomes:
3 Please provide the inspection details of the radome.

4
5

6 A. Radomes are visually inspected each year, or as soon as practical after any severe
7 storm that might have affected a particular site. A visual inspection may also be
8 required as part of any corrective maintenance investigation into any loss or
9 degradation of signal that may have been caused by a radome tear damaging the
10 feed horn assembly. The radomes are inspected for any tears in the radome and
11 any failure of the mounting hardware. Any tears in the radome require a
12 replacement.