

1 Q. Re: 2013 Capital Projects 200,000 and Over but less than 500,000:  
2 Explanations, pages D-245 through D-254 Replace Radomes:  
3 Hydro outlines that radomes cannot be repaired but must be replaced when  
4 identified. Is there an acceptable amount of damage prior to a replacement  
5 being required?

6

7

8 A. Radomes must be replaced when a tear of any size is visually detected. Even a  
9 small tear is unacceptable as it will become much larger due to the high stresses  
10 caused by wind and other environmental factors including icing.