

1 Q. Re: 2013 Capital Projects 50,000 and Over but less than 200,000:  
2 Explanations, pages D-2 through D-10:  
3 How long has Hydro not been in compliance with the storage and handling of  
4 gasoline and associated products regulations, 2003? Has Hydro sought any  
5 exemption relating to the frequency of dipping outlined in section 18(2)(a)? If not,  
6 why not?

7

8

9 A. Hydro has not been in compliance with the storage and handling of gasoline and  
10 associated products regulations, 2003 since 2005. On March 24, 2010, Hydro  
11 sought an exemption relating to frequency of dipping. This was rejected on the  
12 basis that the requested variance in operator duties did not meet the regulations.