

1 Q. Re: 2013 Capital Projects 50,000 and Over but less than 200,000:
2 Explanations, pages E-129 through E-132 Replace 230 kV Breaker Controls:
3 How long have the breakers that Hydro is seeking to replace at Bottom Brook been
4 discontinued?

5

6

7 A. As replacement of the breakers is not part of this project, this response discusses
8 the obsolescence of the breaker controls. The manufacturer is no longer in
9 business, but Hydro suspects that they have been discontinued for more than ten
10 years.