

- 1 Q. Re: Upgrade Burnt Dam Spillway, Bay d'Espoir, Tab 8:
2 With the system in place, Hydro has outlined an instance where the fuse plug was
3 nearly triggered. Has the fuse plug ever been triggered?
4
5
6 A. The fuse plug at Burnt Dam has never been breached (triggered).