

1 Q. With reference to the Project **C-6, Installation of Variable Frequency Drives on**
2 **Forced Draft Fans - Holyrood**, will this Project have any utility after Holyrood is fully
3 converted to synchronous condenser mode?
4

5
6 A. If the plant at Holyrood is fully converted to synchronous condenser mode the
7 variable frequency drives on the forced draft fans will not be required.