

1 Q. With reference to the Project **C-8, Upgrade Governor Controls Units 1 and 2 –**  
2 **Holyrood**, will this Project have any utility after Holyrood is fully converted to  
3 synchronous condenser mode?  
4

5  
6 A. The turbine controller will not be needed after Holyrood is fully converted to  
7 synchronous condenser mode as the turbine will not be in service.