

Undertaking 127

GT-CA-NLH-005. Explanations for differences between scoring of Pro Energy and PW Power Systems on the following items:

SP11-6 (Exception to Galvanized)

SP11-6 PW Power Systems had qualified in their tender that Exterior steel will be properly preserved for the application - it will not all be hot dipped galvanized. Given the proximity to the salt water, hot dipped galvanizing for exterior steel had been specified. As such, PW Power Systems was assigned a score of 0 for this item.