

**Undertaking 63**

**Undertake to provide how many hours the CT ran in August in order to meet the needs...and the cost that was incurred for doing so.**

The Holyrood CT was in operation for 174.5 hours in August 2015 (August 1-18). It produced 7.2 GWh of energy at a total gross fuel cost of \$1.99 million during this period.