

1 Q. Further to the response to PUB-NLH-137, explain in detail if the Wabush Terminal
2 Station 3rd and 4th expansion is an energy source and provide the capacity
3 available to Hydro, monthly quantity supplied and the average unit costs (demand
4 and energy). Also, explain why these power purchases should be allocated 100% to
5 Distribution Demand rather than to production demand or energy.

6

7

8 A. Please see Hydro's response to PUB-NLH-344. The Wabush Terminal Station 3rd and
9 4th expansion is not an energy source but rather Hydro pays for a share of expenses
10 based on a prorated share of the capacity. The expenses are associated with the 46
11 kV terminal station equipment and include extraordinary items, service fees and
12 weekend inspections. As they are related to terminal station operations, these
13 expenses are 100% allocated to Distribution Demand.