

1 Q. In Attachment 1 to the response to PUB-NLH-1, at page 32 of 45 in Hydro's 2013
2 Capital Budget Application, the note to Table 7-1 states:

3
4 "The HVdc link expansion plan satisfies Hydro's generation planning criteria well
5 beyond the 2031 planning horizon..."

6
7 Does this mean that the Hardwoods Gas Turbine will not be required following the
8 interconnection of the Labrador transmission link to satisfy Hydro's generation
9 planning criteria?

10
11
12 A. Yes, this means that the Hardwoods Gas Turbine will not be required following the
13 interconnection of the Labrador transmission link to satisfy Hydro's generation
14 planning criteria. However, the Hardwoods Gas Turbine is required up to the
15 interconnection, as detailed in the response to NP-NLH-3.