

1 Q. What is the life expectancy of the new lighting stands that Hydro is proposing to  
2 install?

3

4

5 A. The depreciable service life of these assets is 45 years. Hydro would consider  
6 whether these assets could be used at another location after they are no longer  
7 required for use at the Holyrood Marine Terminal.