

1 Q. Page 19, *"For loss of a 230/69 kV transformer at Holyrood the criteria permits the*
2 *operation of the Holyrood combustion turbine and opening of NP 38L to off load the*
3 *remaining unit over peak."*

4

5 Please provide the most recent timeline for the return to service of the Holyrood
6 gas turbine or a replacement unit so that the above noted criteria are not being
7 violated.

8

9

10 A. Hydro is currently planning to have the functionality of the Holyrood combustion
11 turbine permanently reinstated by the end of December 2015.