

1 Q. Reference: Hydro's Reply, page 27, line 18. Please provide documentation  
2 supporting Hydro's statement that "the reason for moving the Newfoundland  
3 Power mobile unit to Holyrood was to keep the ancillary equipment at Holyrood in  
4 a warm state".

5

6

7 A. In December 2013, the Newfoundland Power mobile gas turbine was installed at  
8 Holyrood to provide emergency supply to the Holyrood plant in the event of a  
9 sustained loss of station service power to the plant similar to what occurred in  
10 January 2013. This was described in Hydro's response to PR-PUB-NLH-173. Please  
11 refer to Page 1, lines 20 to 25 and continuing on Page 2, lines 1 to 18 of that  
12 response.

13

14 Also, please refer to Schedule 10, Page 20, lines 23 to 25 of Hydro's March 24, 2014  
15 report entitled *A Review of Supply Disruptions and Rotating Outages: January 2-8,*  
16 *2014*, where it is shown the unit was used for this purpose on January 4, 2014,  
17 following the plant station service interruption at 09:05. It was also used for this  
18 purpose following the plant interruption on January 5, 2014 at 21:27 as noted on  
19 Page 23, line 7 of Schedule 10 of the March 24, 2014 report.

20

21 The expenses related to the Newfoundland Power mobile gas turbine referenced in  
22 Hydro's Reply on page 27 relate to the expenses of the unit in 2014 following its  
23 installation in December 2013 for the above noted purpose.