

1 Q. **Reference: *Combustor Inspection Major and Overhaul, Holyrood Combustion***
2 ***Turbine* report, August 29, 2016, page 5, Table 1**

3 Using the cost estimates in the revised Table 1 provided in response to Request for
4 Information NP-NLH-005, please indicate the average cost for each equivalent start
5 and anticipated actual start for the Holyrood CT over the entire 1600 equivalent
6 start inspection cycle.

7

8

9 A. Using the cost estimates in the revised Table 1 provided in response to Request for
10 Information NP-NLH-005, the average cost for each equivalent start and anticipated
11 actual start for the Holyrood CT over the entire 1600 equivalent start inspection
12 cycle are approximately \$23,850.00 and \$31,000.00, respectively. These values are
13 exclusive of fuel, operation, and routine maintenance costs.