

1 Q. Reference: *2016 Standby Fuel Deferral Application*, Page 9, Table 6.
2 Please provide the annual production from Hydro's Standby Generation for the
3 period 2006 through 2015.

4

5

6 A. The following table provides the annual production amounts (in MWh) from
7 Hydro's Island Interconnected System standby generation for the period 2006 to
8 2015. Note that these are gross production amounts (i.e. includes station service
9 and synchronous condenser consumption).

10

Island Interconnected System Standby Generation Production (MWh)	
Year	Production (MWh)
2006	2,518.7
2007	1,947.0
2008	4,788.0
2009	3,168.4
2010	3,983.3
2011	3,351.4
2012	1,867.2
2013	5,539.8
2014	14,206.3
2015	53,326.4