

1 Q. Consumer Question: For the 170 MW CCCT scheduled for 2022 under the Isolated
2 Island Option, where would it be located and how long would it take to construct?

3
4
5 A. Nalcor has not chosen a site for its 2022 170 MW CCCT installation.

6
7 A siting study for the 2022 170 MW CCCT has not been completed, but It is
8 expected that this unit would be located on the Avalon Peninsula. Given the existing
9 infrastructure at NL Hydro's existing Holyrood facility, this site would be included in
10 any siting study for a new CCCT.

11
12 The construction of this project is expected to take from three to four years, plus
13 the time necessary to obtain approval from the Board of Commissioners of Public
14 Utilities.

15
16 Please refer to *Section 6.7: Combustion Turbine Units* and *Section 8.0: Timing of*
17 *Next Decision* in Exhibit 16 - *Generation Planning Issues July 2010 Update Report* for
18 further information.