

1 Q. If any, please present any fisheries related ramping restrictions or emergency flow  
2 bypass requirements.

3

4

5 A. While Nalcor has not concluded negotiation of the Section 35 *Fisheries Act*  
6 authorization for Muskrat Falls, Nalcor does not expect any fisheries related  
7 ramping restriction. Minimum flow for the plant is expected to be approximately  
8 500 m<sup>3</sup>/s, based on minimum production of 1,425 MW at Churchill Falls.