

1

2 Q. In discussions with Nalcor, it has been determined that the current design load for
3 the HVDC overland transmission line is the 1-in-50 year return period, the standard
4 design criteria for 230 kV transmission lines on the Island. Given the critical
5 importance of the HVDC line, what consideration, if any, has been given to
6 designing it to a higher standard? If no consideration has been given, why not?

7

8

9 A. The design standard for new 230 kV transmission lines on the Island portion of the
10 Province is a 1-in-50 year return period. The basis of design for the overland
11 portion of the HVdc transmission line between Labrador and the Island has its
12 design standard set at the same 1-in-50 year return period.

13

14 Given that the HVdc line will deliver upwards of 800 MW to the Island
15 Interconnected System, consideration has always been given to the reliability of the
16 HVdc line.

17

18 Nalcor's transmission planning criteria for the integration of the Labrador – Island
19 HVdc Link require that the Island Interconnected System recover from a temporary
20 or permanent loss of a single pole and temporary loss of the bipole (i.e. pole to pole
21 fault) with no loss of load. While Nalcor is not currently a member of any reliability
22 organization as a transmission owner/operator, the planning criteria applied are
23 consistent with the North American Electric Reliability Corporation (NERC)
24 transmission planning standards and specifically TPL-001.0.1 System Performance
25 Under Normal Conditions, Table 1. Transmission System Standards – Normal and
26 Emergency Conditions, Category B, event 4. For the event involving loss of one pole
27 of the bipole system, the 2 p.u., 10 minute rating of the healthy pole ensures no
28 loss of load on the Island for the event.

1
2 For permanent loss of the bipole, NERC TPL-001.0.1 Table 1 under category C event
3 4 permits planned/controlled loss of load for the event. In the case of the Labrador
4 – Island HVdc Link the permanent loss of the bipole is recognized as a substantial
5 but infrequent event. In the spirit of the NERC criteria, Nalcor has accepted load
6 loss for the permanent bipole outage. To prevent an entire Island Interconnected
7 System outage for permanent loss of the bipole a special protection scheme (SPS) is
8 contemplated to isolate the Avalon Peninsula loads during the event, thereby
9 leaving central and western Island loads connected to central and western Island
10 generation. This would prevent an island wide outage and would thus permit
11 shorter restoration times. Sensitivity analysis completed under DC1210 indicates
12 that cross tripping and/or over frequency protection may be required for such an
13 SPS. As part of the integration studies being completed in final design the proposed
14 SPS will be further refined.

15
16 Nalcor's reliability analysis also considers the contribution to reliability that would
17 be made by the Maritime Link, the proposed HVdc transmission system between
18 Newfoundland and Nova Scotia.

19
20 This system will have a rated capacity of 500 MW and will have the capability for bi-
21 directional flow. For permanent loss of the entire Labrador – Island Link, power will
22 be imported from the Maritimes via the Maritime Link and sufficient combustion
23 turbine generation started on the Island to supply the Island load. With two
24 independent, geographically separated HVdc lines to the Island, a design load based
25 upon a 1-in-50 year return period for each HVdc line is deemed to provide an
26 acceptable level of reliability to the Island transmission system.