

1 Q. Table 16 on pg. 46 of the Submission gives the Forced Outage Rate for the Labrador
2 Island Link (per pole) as 0.89. Is this on a per pole or bipole basis?

3

4

5 A. Nalcor confirms that 0.89% is on a per pole basis. Each pole was modeled in
6 Strategist independently.