

1 Q. Has the potential application of power system stabilizers within the Newfoundland
2 system been examined in detail? If so, when was it completed and provide a copy
3 of the analysis.

4

5

6 A. The application of power system stabilizers within the Newfoundland electrical
7 system has not been examined in detail. Such a study has not been undertaken
8 because the issues that power system stabilizers are generally used to address
9 (small signal stability issues) are not present in the Newfoundland electrical system.